



CONSTRUCTION MATERIALS

TECHNOLOGIES

Jason R. Simmons
6412 Badger Drive
Tampa, FL 33610
813-621-5777
November 27, 2013

Re: Projects LPI-027-02-01, LPI-032-02-01

To Whom it May Concern:

As part of the above referenced projects, Sikagard 530 with specified accessories has been tested to and has met or exceeded the requirements of Air Barrier Association of America – ABAA Process for Approval of Air Barrier Materials, Accessories and Assemblies for fluid applied membranes both as a material and an assembly.

As part of the Process for Approval, Sikagard 530 performed as indicated when tested in accordance with the following standards:

1. ASTM E 2187 - < 0.004 cfm/sf @ 1.56 lbs/sf
2. ASTM E 2357 - < 0.04 cfm/sf @ 1.56 lbs/sf

Sincerely,

A handwritten signature in blue ink, appearing to read 'Jason R. Simmons', written over a light blue grid background.

Jason R. Simmons

LPI-027-02-02 PRI-CMT Accreditations: IAS TL-189; Miami-Dade 11-0429.05; Florida TST5878; Los Angeles TA24819; CRRC
The test results, opinions, or interpretations are based on the material supplied by the client. This report is for the exclusive use of stated client. No reproduction or facsimile in any form can be made without the client's permission. This report shall not be reproduced except in full without the written approval of this laboratory. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.