

Sika Corporation · 201 Polito Avenue · Lyndhurst, NJ 07071 · USA

CONTACT

Monica Morano Product Sustainability Specialist Mobile: (201)492-0804 morano.monica@us.sika.com

# MANUFACTURER'S CERTIFICATE OF COMPLIANCE: VOC EMISSIONS

Lyndhurst, August 1, 2024

To whom it may concern,

Sikafloor®-1610 has been tested according to California Department of Public Health (CDPH) Standard Method v1.2–2017 and complies with the VOC limits in Table 4-1 of the method. Additionally, the range of total VOCs (TVOC) after 14 days (336 hours) was measured as specified in the CDPH Standard Method v1.2 and is reported as  $\leq 0.5$  mg/m3. The testing results are compliant with the emission requirements for VOCs in school classroom and private office exposure scenarios.

Sika Corporation manufactures Sikaflex®-1610 in its Marion, OH facility along with other two component epoxy-based flooring systems that are formulated using the same set of raw materials. While there may be minor difference in the exact composition in these different formulations, the raw materials from which they are produced remains the same. The list below represents the flooring systems that would be covered under the Sikafloor-1610 emissions test:

Sikafloor®-1610 Sikafloor®-161 Sikafloor®-160 Sikafloor®-264

The details of the testing and performance are presented in the Berkeley Analytical laboratory report 991-005-01A-Jul1318. The Certificate of Compliance pursuant to the laboratory report is attached. The actual report is available upon request.

The green building standards and codes which recognize CDPH Standard Method v1.2 include but are not limited to: USGBC LEED version 4/4.1 BD&C, ID&C, Residential BD&C



PAGES 2/2 DATE Error! Reference source not found.4

Multifamily); The WELL Building Standard, WELL v2, Feature X06; and ANSI/GBI 01-2019 Green Globes Assessment Protocol.

If further information is required feel free to contact me.

Sincerely,

monica morano

Monica Morano

Enclosure



# **COMPLIANCE TESTED** by berkeley analytical

# **VOC Emission Test Certificate**

## Product Name: Sikafloor<sup>®</sup> 1610

Product Sample Information		Certificate Information		
Company:	Sika Corporation	Certificate No:	180713-01	
Company Website:	www.sikausa.com	Certified By:	far: J-	
Product Type:	Floor Coatings		Raja S. Tannous, Laboratory Director	
Date Produced:	4/23/2018	Date:	July 13, 2018	

**Reference Standard:** California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 (Emission testing method for CA Specification 01350)

### Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario <sup>1</sup>	Individual VOCs of Concern <sup>2</sup>		Formaldehyde <sup>3</sup>		TVOC⁴
	Criterion	Compliant?	Criterion	Compliant?	Range
School Classroom	≤½ Chronic REL	YES	≤9.0 μg/m³	YES	≤ 0.5 mg/m <sup>3</sup>
Private Office	≤½ Chronic REL	YES	≤9.0 μg/m³	YES	≤ 0.5 mg/m <sup>3</sup>

### Product Coverage<sup>5</sup>: 294 g/m<sup>2</sup>

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.2-2017)

2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid*.)

3. Maximum allowable formaldehyde concentration is ≤9 µg/m<sup>3</sup>, effective Jan 1, 2012; previous limit was ≤16.5 µg/m<sup>3</sup> (ibid.)

4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m<sup>3</sup>, >0.5 – 4.9 mg/m<sup>3</sup>, and ≥5.0 mg/m<sup>3</sup>

5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

### Standards & Codes Recognizing CDPH Standard Method V1.2 (partial list)

- USGBC LEED Version 4, BD&C, ID&C
- The WELL Building Standard
- ANSI/GBI 01, Green Building Assessment Protocol

**Narrative:** Sika Corporation selected a sample representative of its Sikafloor 1610, a two-component epoxy primer product and submitted it on 6/18/2018 for testing. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.2-2017. The results of the test are presented in Berkeley Analytical report, 991-005-01A-Jul1318.

**Berkeley Analytical** is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, <u>TL-383</u>); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

DISCLAIMER: THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.

©2012 Berkeley Analytical, 815 Harbour Way South, Suite 6, Richmond, CA 94804 / 510-236-2325 / www.berkeleyanalytical.com