

NOTES:

- 1) EXISTING CABLE SHALL BE CLEANED FREE OF ASPHALT CONTAMINATION AS REQUIRED PRIOR TO REINSTALLATION.
- 2) IF ASPHALT CONTAMINATION CAN NOT BE CLEANED, SIKA SARNAFIL REQUIRES A CONTINUOUS LAYER OF G459 FLASHING UNDER LOCATION OF CABLE. HOT—AIR WELDED IN—PLACE.
- 3) SIKA SARNAFIL IS NOT RESPONSIBLE FOR LIGHTNING DAMAGE TO SARNAFIL ROOF.
- 4) VAPOR RETARDER SHALL BE SEALED AT EDGES.
- 5) SARNATHERM LIGHTGUARD AND SEPARATION LAYER NOT SHOWN FOR CLARITY.

LIGHTNING ROD

