

STEEP SLOPE MEMBRANE FASTENING REQUIREMENTS							
METHOD OF APPLICATION		CAP SHEET END LAP MAXIMUM SPAN ("X")					
SIKASHIELD E54, BASE PLY	SIKASHIELD HB79, CAP SHEET	1/2:12 to 1:12	1:12 to 2:12	2:12 to 3:12	3:12 to 6:12	6:12 to 12:12	GREATER THAN 12:12
HEAT WELDED	HEAT WELDED	n/a	n/a	24'-0"	16'-0"	12'-0"	4'-0"
COLD ADHERED	HEAT WELDED	32'-0"	24'-0"	16'-0"	16'-0"	12'-0"	NR
	COLD ADHERED	32'-0"	24'-0"	16'-0"	16'-0"	12'-0"	NR
n/a = CAP SHEET END LAP SPANS ARE NOT LIMITED. END LAP FASTENING IS NOT REQUIRED							
NR = ASSEMBLY IS NOT RECOMMENDED AT SPECIFIC SLOPE							

## SIKASHIELD MEMBRANE STEEP SLOPE FASTENING



JOB NAME:

**BUILDING TRUST** 

781-828-5400

 SCALE:
 DATE:
 FILE NO.:
 DRW. NO.:

 N.T.S.
 03/25
 SS-SSF-01
 XXX

AS A MEMBRANE MANUFACTURER, SIKA CORPORATION ("SIKA") REVIEWS DETAILS PREPARED BY THE CONSULTANT, ARCHITECT AND/OR ENGINEER FOR A PROJECT SOLELY FOR THE PURPOSE OF DETERMINING IF A SIKA WARRANTY MAY ISSUE FOR THE PROJECT, THIS REVIEW IS NOT TO BE CONSTRUED AS APPROVAL OF DETAILS BY SIKA AND IS NOT BEING CONDUCTED IN LIEU OF SOUND ENGINEERING AND ARCHITECTURAL PRACTICES AND JUDGMENT AND SHOULD NOT BE RELIED UPON FOR THAT PURPOSE, SIKA CORPORATION ASSUMES NO LIABILITY WITH RESPECT TO THE DESIGN OF THE PREPARATION AND APPROVAL OF THE DETAILS AND SHOP DETAILS, AND SHOP DETAILMING THE DESIGN OF THE ROLL OF A PARTICULAR PROJECT OR APPLICATION, WHILE SIKA PROVIDES GENERAL INSTRUCTIONS FOR THE INSTALLATION OF ITS MEMBRANE AS WELL AS TRAINING FOR SIKA AUTHORIZED APPLICATORS, THE MEANS AND METHODS USED BY THE CONTRACTOR FOR SURFACE PREPARATION AS WELL AS THE MEANS AND METHODS SHEPLOYED BY THE CONTRACTOR IN THE INSTALLATION OF THE SIKA MEMBRANE ARE THE RESPONSIBILITY OF THE CONTRACTOR, ALL SALE OF SIKA PRODUCTS AND SERVICES ARE SUBJECT TO SIKA'S TERMS AND CONDITIONS OF SALE AVAILABLE AT USA.SIKA.COM/SARNAFIL.