

# Sika Sarnafil

*World Class Roofing and Waterproofing*

## ROOFING TECHNICAL BULLETIN

**#05-09**

To: Authorized Roofing Applicators  
Sika Sarnafil Sales Staff & Sales Representatives  
Sika Sarnafil Regional Technical Staff  
Sika Sarnafil Customer Service Staff  
Sika Sarnafil Services Staff

From: Technical Service Department

Re: Solvent Based Adhesives and Polystyrene Insulation

---

Effective immediately, Sika Sarnafil will not approve the use of solvent based adhesives with any system using polystyrene insulation.

We have found in certain situations when using a solvent based adhesive, the solvent will drive down through the cover board causing damage to the polystyrene.

When using polystyrene insulation within a Sika Sarnafil adhered application the only acceptable adhesives are; Sarnacol 2121, Sarnacol 2166, Sarnacol LR2001. Another option is to use the Sika Sarnafil G410 Peel and Stick membrane



Sika Sarnafil, A Division of Sika Corporation, 100 Dan Road, Canton, MA 02021  
Tel. 800-451-2504, Fax: 781-828-5365, [www.sikacorp.com](http://www.sikacorp.com)

**Sarnafil**®