



NOTES:

- 1) NAILERS SHALL BE SECURELY ANCHORED TO THE DECK TO RESIST A MINIMUM FORCE OF 300 POUNDS PER LINEAR FOOT. FOLLOW FACTORY MUTUAL LOSS PREVENTION DATA SHEET 1-49 RECOMMENDATIONS.
- 2) THE THICKNESS OF THE NAILER SHALL MATCH THE HEIGHT OF THE INSULATION OR SURFACE TO WHICH THE MEMBRANE IS TO BE APPLIED.
- 3) VAPOR RETARDER SHALL BE SEALED AT EDGES.
- 4) CONTINUOUS CLEAT IS REQUIRED IF FACE DIMENSION OF FASCIA EXCEEDS 3 INCHES.
- 5) FACE DIMENSION OF FASCIA SHALL BE A MINIMUM OF 3 INCHES OR AS OTHERWISE REQUIRED TO EXTEND A MINIMUM OF 1-1/2 INCHES BELOW BOTTOM OF WOOD NAILER.
- 6) THE HORIZONTAL FLANGE OF THE METAL EDGE SHALL NOT EXTEND BEYOND THE WOOD NAILER.
- 7) FASCIA MAY BE FORMED WITH AN OPTIONAL WATER DAM/GRAVEL STOP.
- 8) NAILS USED TO ATTACH EITHER THE CONTINUOUS CLEAT OR FASCIA SHALL PENETRATE THE NAILER A MINIMUM OF 1-1/2 INCHES. SCREWS SHALL PENETRATE A MINIMUM OF 1 INCH.
- 9) APPROVED UP TO 20 YEAR SIKAPLAN WARRANTY COVERAGE.
- 10) THIS DETAIL ONLY QUALIFIES FOR SIKAPLAN SYSTEM WARRANTIES.

SIKAPLAN SARNACLAD METAL EDGE IN ADHERED SYSTEMS

BUILDING TRUST

781-828-5400



usa.sarnafil.sika.com

JOB NAME:

SCALE: N.T.S.

DATE: 6/16

FILE NO.: SP-1-1A

DRW. NO.: XXX

AS A MEMBRANE MANUFACTURER, SIKA CORPORATION ("SIKA") REVIEWS DETAILS PREPARED BY THE CONSULTANT, ARCHITECT AND/OR ENGINEER FOR A PROJECT SOLELY FOR THE PURPOSE OF DETERMINING IF A SIKA WARRANTY MAY ISSUE FOR THE PROJECT. THIS REVIEW IS NOT TO BE CONSTRUED AS APPROVAL OF DETAILS BY SIKA AND IS NOT BEING CONDUCTED IN LIEU OF SOUND ENGINEERING AND ARCHITECTURAL PRACTICES AND JUDGMENT AND SHOULD NOT BE RELIED UPON FOR THAT PURPOSE. SIKA CORPORATION ASSUMES NO LIABILITY WITH RESPECT TO THE DESIGN OF THE ROOFING OR WATERPROOFING SYSTEM, THE ARCHITECT, CONSULTANT AND/OR ENGINEER OR DESIGN PROFESSIONAL FOR A PARTICULAR PROJECT BEARS THE SOLE RESPONSIBILITY FOR THE DESIGN OF THE ROOFING OR WATERPROOFING SYSTEM, FOR THE PREPARATION AND APPROVAL OF THE DETAILS AND SHOP DRAWINGS, AND FOR DETERMINING THEIR SUITABILITY FOR A PARTICULAR PROJECT OR APPLICATION, WHILE SIKA PROVIDES GENERAL INSTRUCTIONS FOR THE INSTALLATION OF ITS MEMBRANE AS WELL AS TRAINING FOR SIKA AUTHORIZED APPLICATORS, THE MEANS AND METHODS USED BY THE CONTRACTOR FOR SURFACE PREPARATION AS WELL AS THE MEANS AND METHODS EMPLOYED BY THE CONTRACTOR IN THE INSTALLATION OF THE SIKA MEMBRANE ARE THE RESPONSIBILITY OF THE CONTRACTOR. ALL SALE OF SIKA PRODUCTS AND SERVICES ARE SUBJECT TO SIKA' TERMS AND CONDITIONS OF SALE AVAILABLE AT USA.SARNAFIL.SIKA.COM.