



December 13, 2013

Mr. Timothy Gillespie
SIKA CORPORATION
201 Polito Avenue
Lyndhurst, New Jersey 07071

RE: SIKAGARD® 535

Dear Mr. Gillespie:

Architectural Testing, Inc. has completed their evaluation of Sikagard® 535 liquid-applied membrane in accordance with select requirements of the Air Barrier Association of America (ABAA). The product was evaluated for Water Resistance per AATCC 127, Nail Sealability per ASTM D 1970, Pull-off strength from concrete and Glass Fiber Gypsum Sheathing per ASTM D 4541, and Water Vapor Permeance per ASTM E 96, Methods A and B. Sikagard® 535 liquid-applied membrane met all ABAA requirements for these properties.

If you need any additional information, or if I can be of further assistance, please contact me.

ARCHITECTURAL TESTING, INC.:

Gary Hartman, P.E. - Director
Component/Materials Testing
Architectural Testing, Inc.

GH:jas
cc: D1420.02-106-31